

Challenges in Designing Electricity Spot Markets

Mete Şeref Ahunbay

Martin Bichler

Johannes Knörr*

August 26, 2024

Abstract

Electricity markets have drawn significant attention due to their size, their importance for the economy, and the intricacies in their design. Non-convexities in the valuation and cost functions render the allocation and pricing problems computationally difficult, and lead to non-existence of equilibrium in general. In addition, these markets need to consider power flows on the electricity network, which further distinguishes them from many other markets. Increasing levels of renewable energy sources such as wind and solar lead to new requirements. The integration of renewable energy sources such as wind and solar, particularly important for the energy transition needed to meet climate targets, necessitates further advances. In particular, the volatility of renewable supply requires attention. We discuss some of the central issues in the design of electricity spot markets and possible solutions that were discussed in the recent literature.

1 Introduction

Electricity markets globally, especially in Europe and extensive regions of the United States, have transitioned from being monopolistic to adopting a competitive wholesale market structure, a shift that primarily occurred in the 1990s. Presently, short-term electricity purchases in these jurisdictions are facilitated through power exchanges. These platforms are integral in establishing core pricing signals for both over-the-counter transactions and futures markets, as outlined by Shah and Chatterjee (2020). In the United States, notable examples of these power exchanges encompass the California Independent System Operator (CAISO), the Electric Reliability Council of Texas (ERCOT), the Midwest ISO (MISO), the New York ISO (NYISO), and the ISO New England (ISO-NE). These markets typically facilitate the trading of hourly products for the subsequent day in the day-ahead markets. After the day-ahead markets, the market operators use real-time markets in the United States (or intraday markets in Europe) to deal with changes in supply and demand that are closer to the actual dispatch. We will distinguish these types of *electricity spot markets* from *futures markets* where participants can hedge against longer-term price risks.

Spot markets are significant in size. In 2020, European coupled day-ahead markets alone cleared 1,530 TWh in 27 countries with average prices between 30 and 40 EUR/MWh (NEMO Committee 2021). Similarly, the cost of serving load amounted to \$8.9 billion in the Californian market, covering 26,000 circuit miles, roughly 1,000 power plants, a population of 30 million, and about 9,700 pricing nodes (California ISO 2018, 2021). While many aspects of electricity market design are similar to other commodity markets, a few features stand out.

*Technical University of Munich, School of Computation, Information and Technology, Department of Computer Science. E-mail: mete.ahunbay/bichler/knoerr@cit.tum.de

- First, at the moment of dispatch, demand and supply have to be balanced. This is since both excess and inadequate supply destabilizes the voltage and frequency on the electricity grid, potentially leading to blackouts.
- Second, demand and supply meet on the nodes of the power grid, and excess supply can be shipped to neighbouring nodes via transmission lines.
- Third, electricity markets are characterized by non-convex preferences. For example, electricity suppliers often incur fixed costs for starting up and running their generators. On the demand side, industrial customers typically need a certain volume of electricity over consecutive hours to finish production or maintain energy-intensive services. Such consumption profiles can sometimes be shifted over time, but the profiles themselves must not be altered. Non-convexities in the preferences of this sort lead to non-convex optimization problems that need to be solved in order to determine the efficient (welfare-maximizing) dispatch and prices. We will use the term *non-convex markets* in what follows.

The landscape of power systems is undergoing a transformation due to the influx of renewable energy sources (RES). A significant portion of this new capacity is attributed to Variable Energy Resources (VER) like solar and wind power. These energy sources, characterized by their inherent variability and unpredictability, necessitate the incorporation of flexible demand to ensure grid stability and reliability (Reihani et al. 2016). Demand response is the most immediately available way of increasing demand flexibility and the cheaper option compared to storage technologies today (EU 2016). For example, industrial processes for the production of pulp and paper are able to provide demand response with a duration of up to three hours without any notice time (EU 2016). Still, this flexibility comes at a cost and bidders want lower prices if they provide more flexibility.

The traditional literature on electricity market pricing typically relies on the assumption of price-inelastic demand, but this assumption is unlikely to hold in the future (Herrero et al. 2020). It is expected that in the future we will see more price-responsive demand (Hytowitz et al. 2020). However, such price-sensitive bids for flexible demand make market design more challenging. First, new bid formats lead to additional non-convexities which can affect price formation. Second, prices that are individually rational and clear the market at the efficient dispatch cannot always be budget balanced anymore (Bichler et al. 2022). Overall, we move to an economy with many thousands of small generators and a more price-sensitive demand side that actively bids in electricity markets and offers flexibility to cope with variability in the supply (IRENA 2019, Hytowitz et al. 2020).

Such changes in the market have led to renewed interest in the design of electricity markets. We start out discussing standard notions of market equilibrium, before we survey the literature on electricity market pricing and some of the current research challenges.

2 Competitive Equilibrium on Markets

The literature on electricity markets draws on insights from general equilibrium theory. The Arrow-Debreu model shows that under convex preferences, perfect competition, and demand independence, there must be a set of competitive equilibrium prices (Arrow and Debreu 1954, McKenzie 1959, Gale 1963, Kaneko 1976). The results derived from the Arrow-Debreu model led to the well-known

welfare theorems, representing important arguments for markets to be used as efficient or welfare-maximizing means to allocate scarce resources such as electricity. The first theorem states that any Walrasian equilibrium leads to a Pareto efficient allocation of resources. The second theorem states that any efficient allocation can be attained by a Walrasian equilibrium under the Arrow-Debreu model assumptions (Mas-Colell et al. 1995). Walrasian equilibrium prices are such that there is a single price for each product (i.e., prices for a package are *linear*) and this is the same price for all participants (i.e., *anonymous* prices with no price differentiation). The question is then whether electricity markets indeed admit a Walrasian equilibrium.

One feature of electricity markets is that they are based on a network with possibly thousands of spatially distributed nodes connected via transmission lines. To put it differently, we have a set of coupled markets and need to equalize supply and demand at each node.

Definition 1 (Ahunbay et al. (2023b)). A *coupled market* consists of a set of goods M , a set of transmission network parameters F and a set of market participants $L = B \cup S \cup R$, partitioned into the set of buyers B , set of sellers S and the set of transmission operators R . Each market participant $\ell \in L$ has preferences over bundles in $\mathbb{R}^{M \cup F}$, i.e. each buyer b has a valuation function $v_b : \mathbb{R}^{M \cup F} \rightarrow \mathbb{R}$, each seller s has a cost function $c_s : \mathbb{R}^{M \cup F} \rightarrow \mathbb{R}$, and each transmission operator r has a cost function $d_r : \mathbb{R}^{M \cup F} \rightarrow \mathbb{R}$.

Thus, we also need to price transmission lines in such coupled markets appropriately (L  t   et al. 2022). For example, if a transmission line is congested, the price on two adjacent nodes should differ. Similarly, prices on all nodes should be identical if there is no network congestion. So, do the Welfare Theorems hold in coupled markets connected via transmission networks? Fortunately, the answer to this question is affirmative:

Theorem 2.1 (The Welfare Theorems for Coupled and Convex Markets, Ahunbay et al. (2023b)). Let price vector $p^* \in \mathbb{R}^{M \cup F}$ and the allocation $(z_\ell)_{\ell \in L}^*$ be a Walrasian equilibrium, then this allocation maximizes social welfare. Conversely, if $(z_\ell)_{\ell \in L}^*$ is a welfare-maximizing allocation, then it can be supported by a Walrasian price vector p^* that forms a Walrasian equilibrium.

However, this theorem as well as the original welfare theorems assume convex preferences. As we discussed earlier, electricity markets have non-convex preferences and complex constraints. It is well known that only restricted types of valuations (e.g., substitutes valuations or unimodular demand types) allow for convex allocation problems and Walrasian equilibria (Kim 1986, Bikhchandani and Mamer 1997, Leme 2017, Baldwin and Klemperer 2019). Thus, we cannot expect Walrasian equilibria to exist on electricity spot markets.

This raises the question how prices can be computed in the presence of non-convex preferences for indivisible goods and which properties we can hope to achieve compared to Walrasian equilibria. Established market design desiderata are *efficiency* (i.e., maximization of welfare or gains from trade), *individual rationality* (i.e., participants should not make a loss), *budget balance* (i.e., the market operator should not make a loss or a gain), and *envy-freeness* (i.e., participants would not want a different allocation at the prices). These axioms are not only central to economic theory, but are widely adopted and natural design desiderata for practical market design.

If the allocation problem is convex, dual variables for the convex allocation problem provide a principled way to determine competitive equilibrium prices that satisfy these desiderata (Bichler et al. 2020). In non-convex markets, it is well known that competitive equilibrium prices might need to be non-linear and personalized and such prices might not even exist (Bikhchandani and

Ostroy 2002, Bichler and Waldherr 2019). Thus, in a combinatorial auction or exchange that allows for supply and demand bids on packages of items, each bidder might need to face a different price for the same package (personalized prices), and each package price could differ from the sum of the item prices in this package and the price of each package may differ from the sum of the prices of each constituent item (non-linear prices). In electricity markets, each item corresponds to electric power delivered at a certain hour and location, and the presence of non-convexities can render market clearing with linear and anonymous prices impossible. As a simple example, consider a single supplier with an (indivisible) sell bid of 2 MWh for \$30, while there is one buyer asking for 1 MWh for at most \$10, and another buyer asking for 1 MWh for \$28. Linear and anonymous market prices could not be higher than \$10/MWh. As such there would be no trade and no gains from trade. Only with price differentiation would trade be possible.

However, non-linear and personalized prices would convey little information other than that a bidder has lost or won. Besides, prices should serve as a baseline for financial derivatives such as options or futures, which is hardly possible with non-linear prices that differ among participants. In other words, anonymity and linearity are important requirements for prices on electricity markets but also in other domains (Bichler et al. 2018). This has led to significant research on pricing in non-convex electricity markets.

3 State-of-the-Practice in Electricity Market Pricing

Let us now introduce the pricing rules used in electricity spot markets today. The literature on this subject is large and we only focus on specific pricing rules that have been implemented in practice. The interested reader is referred to Liberopoulos and Andrianesis (2016) for an excellent survey on the topic.

Electricity spot markets are composed of varying levels of “demand” (load) and matching levels of “supply” (generation). Market participants submit supply and demand bids according to a certain *bid language* that determines the form of the allocation problem (which yields the efficient dispatch) and the pricing rule. Ideally, supply and demand curves at each traded time slice (e.g., hour) determine prices in equilibrium. However, sophisticated bid languages are required to express the technical constraints generators face, with consequences on the allocation problem (which yields the efficient dispatch) and the pricing rule (Herrero et al. 2020). For example, in markets in the United States (U.S.), generators can express start-up or no-load costs, economies of scale (by means of piecewise-linear cost functions), or minimum-generation requirements. The resulting bid languages then translate into non-convex allocation problems (Herrero et al. 2020).

In 2005, the Pennsylvania, Jersey, Maryland Power Pool (PJM) introduced mixed-integer programming (MIP) in order to address these non-convexities and to determine the efficient allocation or dispatch (O’Neill et al. 2020). Since 2018, all Independent System Operators (ISOs) in the U.S use MIPs to compute the efficient dispatch instead of the Lagrangian relaxation that was used before. The MIP used to solve the allocation problem on US electricity markets is also known as Direct Current Optimal Power Flow (DCOPF) problem. Dual prices as they are accessible for convex optimization problems are not available in such markets, which led to a fundamental question: How can market prices per hour be computed in such non-convex markets? What are meaningful prices in such non-convex markets and how can they be computed?

One approach followed by European day-ahead markets is to sacrifice efficiency. The EU-PHEMIA algorithm that is used to clear European day-ahead markets first solves a welfare max-

imization allocation problem as a mixed-integer program and then iteratively tries to find linear and anonymous prices that clear the market. If such prices cannot be found, additional constraints are added to the welfare maximization problem (NEMO Committee 2020). However, it is unclear how much of the gains from trade are sacrificed this way. Furthermore, this approach inevitably leads to paradoxically rejected bids (Meeus et al. 2009). In particular, there are generators with an ask price that is less than the market price, yet they will not be dispatched. Such prices are thus not *envy-free* and hence do not constitute a Walrasian equilibrium. By its design as an iterative algorithm, EUPHEMIA further faces considerable computational challenges, magnified by the impending introduction of 15 minute market time units in the European electricity markets in 2025. We shall hence not further discuss this approach here, and focus on market designs as in the U.S. that implement the efficient outcome.

Several pricing rules have been suggested aiming to mimic competitive equilibrium prices on such MIP-based electricity markets (Liberopoulos and Andrianesis 2016). Locational marginal pricing (LMP) rules of many ISOs are based on IP pricing (aka. Integer Programming pricing), where the allocation problem is solved to optimality, the integer variables are fixed, and the prices are then derived from the dual variables of the demand-supply constraint of the resulting (convex) linear program (O’Neill et al. 2005). IP pricing computes anonymous and linear prices, but these prices do not constitute competitive equilibrium prices. Some generators might not maximize their individual profits and want to deviate, i.e., switch to a different dispatch at those prices, and IP prices are thus not *envy-free*. The latter is central to the definition of a competitive equilibrium and it leads to stability of the outcome. Importantly, besides a lack of stability, the generators often make a loss at the IP prices, i.e., prices are not even *individually rational*.

Another prominent pricing rule for electricity markets considered in academic literature is *Convex Hull* (CH) *pricing* (Hogan and Ring 2003, Gribik et al. 2007), which aims to minimize envy and thus implement a stable outcome and thus maximize the stability of the welfare optimal outcome at the expense of budget balance. We refer to incentives to deviate from the optimal outcome as *lost opportunity costs*, LOCs. They describe the difference between each participant’s profits under the welfare-maximizing allocation and the individual profit maxima each participant could obtain given the prices. With CH pricing, the market operator implements the optimal outcome and compensates participants for their LOCs (violating budget-balance). This way, market participants would not have an incentive to deviate. For certain bid languages, CH pricing is equivalent to Extended LMP (ELMP), a pricing rule used by some US ISOs. ELMP is based on the dual variables from the supply-demand constraint in the LP relaxation of the underlying DCOPF. However, market participants can also make a loss with ELMP, and they need to be compensated.

ISOs use personalized side-payments to address the fact that the public market prices from IP pricing or ELMP are neither envy-free nor individually rational. This effectively differentiates the linear and anonymous market prices from the payments of the market participants, which are then non-linear and personalized. LOCs are differentiated from *make-whole payments* (Schiro et al. 2016). LOCs describe payments that are so high that no generator would want to change its dispatch and envy-freeness is achieved. Such payments may be very large if the market contains non-convexities (Eldridge et al. 2019). However, electricity markets are highly regulated markets and as such there are alternative means to enforce stability other than high LOC payments. Actually, most ISOs only pay make-whole payments to ensure individual rationality of all generators and stipulate penalties that a generator has to pay if it indeed deviates from the optimal dispatch. In other words, they relax envy-freeness to only individual rationality requirements. We refer to such

outcomes as having *penalty-based stability*.

However, even the make-whole payments are a significant concern (Hytowitz et al. 2020). The U.S. Federal Energy Regulatory Commission (FERC) regulates the U.S. wholesale power markets to promote just competition. In 2018, the FERC found that the practices of several ISOs were unjust and ordered them to change their pricing because prices did not accurately reflect the cost of serving load (O’Neill et al. 2019). Moreover, make-whole payments are not reflected in the public price signals, which results in biased investment signals. This hence constitutes a problem for futures markets, where spot market prices serve as the key reference. This has led FERC to release several orders and notices on pricing, which argue that “the use of side-payments can undermine the market’s ability to send actionable price signals.”¹ Similarly, O’Neill et al. (2019) state that “the make-whole payments are not transparent to other market participants and are allocated too broadly to provide correct price incentives for market participants to make efficient entry and exit decisions as well as efficient investments in facilities and equipment.”. As a consequence, US ISOs continue to search for improvements in the pricing rules.

4 Dealing with Non-Convexities

In what follows, we discuss some of the current developments and research frontiers in electricity spot market design. We will discuss new ways how to deal with non-convexities and approaches to deal with the volatility of supply in future electricity markets.

4.1 Non-Convexities in Supply and Demand

We have discussed that in non-convex markets, a Walrasian competitive equilibrium does not exist in general (Starr 1969, Bikhchandani and Mamer 1997). Current pricing rules as they were discussed in the previous section violate either envy-freeness or budget-balance or both. One might wonder whether existing pricing rules used in electricity markets can be improved upon. One way forward is to break down envy-freeness in the context of electricity markets and consider different types of LOCs (Ahunbay et al. 2023b).

Rather than minimizing LOCs as incentives to deviate, hereafter referred to as *global* LOCs (GLOCs), one may look at so called *local* LOCs (LLOCs), and at the specific considerations required to price a coupled market. Specifically, in a coupled market, *transmission* has to be priced appropriately. For example, prices should only differ across a pair of nodes if there is *congestion* in the network and no further power may be transmitted from the node with the higher price to that with a lower price. Violations of this condition, i.e. price differences across uncongested branches, may result in a product revenue shortfall for transmission operators which would require compensation. CH pricing does not satisfy this requirement (Schiro et al. 2016), but it is important to consider for a pricing rule.

It turns out that *local lost opportunity costs* describe a way to consider the quality of congestion prices. LLOCs measure incentives to deviate from the optimal allocation *under fixed commitment*.² In other words, LLOCs assume that the commitment decisions have been made but that generators

¹<https://www.ferc.gov/industries-data/electric/electric-power-markets/energy-price-formation>

²Commitment decisions on spot markets determine whether a generator is scheduled to produce electricity during a market time unit (a binary decision variable in the allocation problem), but not the production quantity (in Megawatt hours (MWh)). Commitment decisions occur because many types of generators require a long time to turn on/off.

can deviate from their assigned volumes in an attempt to improve their payoff. Interestingly, minimizing LLOCs also provides for the desired congestion signals in the network, in the sense that prices reflect the marginal value of additional transmission capacity.

Unfortunately, low GLOCs, LLOCs, and MWPs are conflicting design goals and optimizing only one of these classes comes at the expense of another. If MWPs are minimized, GLOCs can be unreasonably high and congestion signals become distorted leading to high LLOCs. Focusing only on LLOCs can be equally harmful and lead to very high MWPs for some participants. This is striking, as IP Pricing and CH Pricing in fact correspond to minimizing respectively LLOCs and GLOCs. Ahunbay et al. (2023b) suggest the join pricing rule, which balances trade-offs between MWPs and LLOCs to minimize incentives of participants to locally deviate from the efficient outcome as well as their incentives to exit the market. Numerical experiments show that prices computed via this join require significantly less MWPs than traditional IP pricing and retain good congestion signals with very low LLOCs at the same time. The approach can be computed efficiently and it requires no fine-tuning of objective weights. In electricity markets, where global incentives to deviate can be enforced by penalizing deviations, the join strikes a desirable balance, and the experiments show that the remaining incentives to deviate are low.

4.2 Non-Convexities from Non-Linear Power Flows

The literature on electricity market pricing so far focused mainly on non-convexities arising from the cost or valuation functions of market participants. The line losses are linearized leading to a mixed-integer linear program, the DCOPF. However, an accurate representation of the physics governing the transmission network would require the consideration of non-linear line losses. As a result, the allocation problem is accurately described instead as a non-linear and non-convex optimization problem referred to as Alternating Current Optimal Power Flow (ACOPF) problem (Molzahn and Hiskens 2019). This ACOPF is computationally intractable for the problem sizes that we observe in real-world electricity markets. This is the main reason why linearized network models as the DCOPF are used for market clearing and pricing. Unfortunately, the optimal solution for DCOPF is generally neither AC-optimal nor AC-feasible. This requires market operators or transmission system operators (TSOs) to adjust the dispatch after the market clearing to reach a physically feasible outcome.

This issue is magnified by the transition to renewable energy sources (Lété et al. 2022). A decreasing amount of thermal generators can supply reactive power and the consideration of reactive power on the transmission level is therefore crucial (Hemmati et al. 2013, Karmakar and Bhattacharyya 2020). Larrahondo et al. (2021) found that high integration of wind power contributes to the inaccuracies of the DCOPF by disregarding *reactive power*. As the amount of thermal generators that can supply reactive power is also decreasing, the consideration of reactive power on the transmission level is crucial (Hemmati et al. 2013, Karmakar and Bhattacharyya 2020). There have been significant efforts to obtain tighter and more accurate relaxations of the ACOPF problem in an effort to leverage recent advances in convex optimization for real-world markets, which culminated in the ARPA-E Grid Optimization Competition.³ However, errors in the optimization models due to linearization or simplifying assumptions remain a concern in virtually all electricity markets. For example, the revision of the European Capacity Allocation and Congestion Management (CACM) regulation requires accounting for “linearisation errors” while calculating available capacities for

³See <https://gocompetition.energy.gov/> for further details.

trading (ACER 2021). A key problem of linearized models is the welfare loss arising from a poor approximation of ACOPF.

In recent years, substantial research has been devoted to finding tighter convex relaxations and approximations for the ACOPF problem (Molzahn and Hiskens 2019). This research focuses on the optimality of the solution and computational costs to obtain it. Tighter relaxations of ACOPF could lead to prices that better reflect scarcity in the physical network. However, the magnitude of these improvements is unclear. Bichler and Knörr (2023) study the impact of non-linear convex market clearing models on prices, MWPs and LLOCs. More precisely, they consider the linearized DCOPF, a second-order conic (SOC) relaxation, and a quadratic convex (QC) relaxation (Molzahn and Hiskens 2019). For each relaxation, they compute market clearing prices via IP and CH pricing rules. The results show that different power flow models lead to substantial differences in the allocation. This of course has an impact on both welfare and prices.

As one would expect, tighter convex relaxations require substantially less redispatch compared to the standard DCOPF approximation. Moreover, MWPs, GLOCs and LLOCs are on average lower for the final AC-feasible outcome. The tighter convex relaxations also lead to higher welfare of the final dispatch. However, welfare gains are not the most important argument for tighter convex relaxations of ACOPF. The numerical experiments show that the prices obtained from DCOPF are often substantially different from those of the non-linear relaxations, leading to biased scarcity signals that distort effective demand response and investment decisions. In contrast, the results of the SOC and QC relaxation, which both model reactive power and line losses more accurately, are almost identical. Prices obtained from DCOPF might be excessively high at some of the nodes, even though there is no congestion in the AC-feasible solution. In other words, the DCOPF leads to unnecessary price peaks at some of the nodes even though there is no congestion in the physical grid at all. Similarly, we might encounter congestion in the AC-feasible solution that the DC prices of adjacent nodes do not reflect. In a world with 100% renewables, where adequate demand response is even more important, this is a decisive disadvantage of standard DCOPF solutions compared to tighter non-linear relaxations.

4.3 Outlook

While increasing levels of storage suggest that the allocation problem becomes more convex, non-convexities will remain an important concern for a long time. Startup costs of gas turbines, minimum operating levels, minimum run times and down times will also play a role in the foreseeable future. In this short paper, we could only discuss a few of the approaches to address different types of non-convexities on electricity markets. Other ideas revolve around the use of price differentiation or the use of two price vectors (O'Neill et al. 2019, Eldridge et al. 2020, O'Neill et al. 2016, Hytowitz et al. 2017, Milgrom and Watt 2021, Ahunbay et al. 2023a).

The volatility of renewable energy sources creates uncertainties in the day-ahead prices of electricity markets. Unlike dispatchable generators, which can ensure a specific amount of electricity production, wind and solar generators cannot provide such guarantees. Some authors suggest robust optimization to minimize cost in such stochastic environments (Zugno and Conejo 2015, Li et al. 2018, Silva-Rodriguez et al. 2022). Also stochastic clearing was suggested in the day-ahead market to better deal with the volatility of supply and demand in markets with large proportions of renewables (Zavala et al. 2017, Uçkun et al. 2015). How prices are determined in the presence of robust or stochastic market clearing is not yet well understood (Eldridge et al. 2021, Bertsimas and Koulouras 2024).

In particular in zonal markets such as the EU power market, the concept of local flexibility markets has been explored (Jin et al. 2020, Olivella-Rosell et al. 2018, Cramton 2022). The local flexibility market allows system operators to procure additional flexibility close to real time, which helps in managing unexpected grid conditions or fine-tuning the grid balance in response to real-time developments. After the day-ahead market has determined the initial energy dispatch based on expected supply and demand, local flexibility markets step in to address any emerging needs, such as intrazonal congestion or other grid constraints that were not fully resolved or anticipated in the day-ahead market. For example, a Distribution System Operator sends a request which includes specific requirements, such as the amount of load reduction or generation increase needed. Participants (e.g., households with batteries, electric vehicles, or small-scale generators) then submit bids indicating the amount of flexibility they can provide and at what price.

One of the concerns with such markets is gaming, which refers to participants’ misrepresentation of their costs and valuations in order to increase their profit. The typical source of gaming arises from the structure of the market, partitioned into forward markets where futures are traded, the day-ahead market, and the intraday market. Poor choice of regulation can then allow for arbitrage between different markets, leading to what is known as *inc-dec gaming* in literature (Hirth et al. 2019). How a more *incentive compatible* and practical electricity market can be designed, in which participants have limited incentive to misrepresent their preferences, is an open problem. A deeper, related question is whether market participants can *learn* to game the market, and how the resulting market distortion may be limited. Byers and Eldridge (2022) show that generators may learn to self-schedule or self-commit to increase their own profit, using very simple learning algorithms with no particular knowledge of the market at large. Such strategic bidding results in increased profit for the generators with consumers bearing the additional cost. This motivates further investigation into whether such learned strategic behavior exists in practice, its effects on prices and efficiency, and how it may be limited.

Changes on electricity markets are not only relevant for market operators, but they also impact generators, industrial and retail consumers alike. How to best design power markets such that they address the challenges of volatile supply of renewables continues to be a challenging research field at the intersection of computer science, economics, and operations research.

Acknowledgments

The financial support from the German Research Foundation (Deutsche Forschungsgemeinschaft, DFG) (BI 1057/10-1) is gratefully acknowledged.

References

- ACER (2021) ACER recommendation 02-2021 on CACM 2.0: Annex 4 - CACM reasoning. URL https://acer.europa.eu/Official_documents/Acts_of_the_Agency/Recommendations%20Annexes/ACER%20Recommendation%2002-2021%20on%20CACM/ACER%20Recommendation%2002-2021%20on%20CACM%20-%20Annex%204%20-%20CACM%20Reasoning.pdf.
- Ahunbay MŞ, Bichler M, Dobos T, Knörr J (2023a) Solving large-scale electricity market pricing problems in polynomial time. *TUM Working Paper*.
- Ahunbay MŞ, Bichler M, Knörr J (2023b) Pricing optimal outcomes in coupled and non-convex markets: Theory and applications to electricity markets. *ACM Conference on Economics and Computation*.

- Arrow KJ, Debreu G (1954) Existence of an equilibrium for a competitive economy. *Econometrica: Journal of the Econometric Society* 265–290.
- Baldwin E, Klemperer P (2019) Understanding preferences: demand types, and the existence of equilibrium with indivisibilities. *Econometrica* 87(3):867–932.
- Bertsimas D, Koulouras AG (2024) Adaptive pricing in unit commitment under load and capacity uncertainty. *IEEE Transactions on Power Systems* 38(3).
- Bichler M, Fichtl M, Schwarz G (2020) Walrasian equilibria from an optimization perspective: A guide to the literature. *Naval Research Logistics (NRL)* .
- Bichler M, Fux V, Goeree J (2018) A matter of equality: Linear pricing in combinatorial exchanges. *Information Systems Research* 29(4):1024–1043.
- Bichler M, Knoerr J, Maldonado F (2022) Pricing in non-convex markets: How to price electricity in the presence of demand response. *Information Systems Research* 1(to appear).
- Bichler M, Knörr J (2023) Getting prices right on electricity spot markets: On the economic impact of advanced power flow models. *Energy Economics* 126:106968.
- Bichler M, Waldherr S (2019) Computing core-stable outcomes in combinatorial exchanges with financially constrained bidders. *Proceedings of the 2019 ACM Conference on Economics and Computation*, 747–747 (ACM).
- Bikhchandani S, Mamer JW (1997) Competitive equilibrium in an exchange economy with indivisibilities. *Journal of Economic Theory* 74(2):385–413.
- Bikhchandani S, Ostroy JM (2002) The package assignment model. *Journal of Economic Theory* 107(2):377–406.
- Byers C, Eldridge B (2022) Auction designs to increase incentive compatibility and reduce self-scheduling in electricity markets. *arXiv preprint arXiv:2212.10234* .
- California ISO (2018) ISO at-a-glance. <https://www.caiso.com/Documents/CaliforniaISO-GeneralCompanyBrochure.pdf>.
- California ISO (2021) 2020 annual report on market issues & performance. URL <http://www.caiso.com/Documents/2020-Annual-Report-on-Market-Issues-and-Performance.pdf>.
- Cramton PC (2022) Local flexibility market. Technical report, ECONtribute Discussion Paper.
- Eldridge B, Knueven B, Mays J (2021) Efficient prices under uncertainty and non-convexity. *Optimization Online*. URL: http://www.optimization-online.org/DB_FILE/2021/04/8338.pdf .
- Eldridge B, O’Neill R, Hobbs BF (2020) Near-optimal scheduling in day-ahead markets: Pricing models and payment redistribution bounds. *IEEE Transactions on Power Systems* 35(3):1684–1694, ISSN 0885-8950, URL <http://dx.doi.org/10.1109/TPWRS.2019.2947400>.
- Eldridge B, O’Neill R, Hobbs BF (2019) Near-optimal scheduling in day-ahead markets: pricing models and payment redistribution bounds. *IEEE transactions on power systems* 35(3):1684–1694.
- EU (2016) Impact assessment study on downstream flexibility, price flexibility, demand response & smart metering. Technical Report ENER/B3/2015-641.
- Gale D (1963) A note on global instability of competitive equilibrium. *Naval Research Logistics Quarterly* 10(1):81–87.
- Gribik PR, Hogan WW, Pope SL, et al. (2007) Market-clearing electricity prices and energy uplift. *Cambridge, MA* .
- Hemmati R, Hooshmand RA, Khodabakhshian A (2013) State-of-the-art of transmission expansion planning: Comprehensive review. *Renewable and Sustainable Energy Reviews* 23:312–319, ISSN 13640321, URL <http://dx.doi.org/10.1016/j.rser.2013.03.015>.
- Herrero I, Rodilla P, Batlle C (2020) Evolving bidding formats and pricing schemes in USA and Europe day-ahead electricity markets. *Energies* 13(19):5020.

- Hirth L, Schlecht I, Maurer C, Tersteegen B (2019) Future redispatch procurement in Germany: Conclusions from the project Beschaffung von Redispatch. URL https://www.bmwi.de/Redaktion/EN/Publikationen/Studien/future-redispatch-procurement-in-germany.pdf?__blob=publicationFile&v=2#:~:text=0n%20the%20redispatch%20market%2C%20they,markets%20or%20as%20arbitrage%20trading.
- Hogan WW, Ring BJ (2003) On minimum-uplift pricing for electricity markets. *Electricity Policy Group*.
- Hytowitz RB, Frew B, Stephen G, Ela E, Singhal N, Bloom A, Lau J (2020) Impacts of price formation efforts considering high renewable penetration levels and system resource adequacy targets.
- Hytowitz RB, O'Neill R, Eldridge B, Castillo A (2017) Multi-period dual pricing algorithm in non-convex ISO markets.
- IRENA (2019) Innovation landscape for a renewable-powered future: Solutions to integrate variable renewables.
- Jin X, Wu Q, Jia H (2020) Local flexibility markets: Literature review on concepts, models and clearing methods. *Applied Energy* 261:114387.
- Kaneko M (1976) On the core and competitive equilibria of a market with indivisible goods. *Naval Research Logistics Quarterly* 23(2):321–337, URL <http://dx.doi.org/10.1002/nav.3800230214>.
- Karmakar N, Bhattacharyya B (2020) Optimal reactive power planning in power transmission network using sensitivity based bi-level strategy. *Sustainable Energy, Grids and Networks* 23:100383, ISSN 23524677, URL <http://dx.doi.org/10.1016/j.segan.2020.100383>.
- Kim S (1986) Computation of a large-scale competitive equilibrium through optimization. *Computers and Operations Research* 13(4):507 – 515, ISSN 0305-0548.
- Larrahondo D, Moreno R, Chamorro HR, Gonzalez-Longatt F (2021) Comparative performance of multi-period ACOF and multi-period DCOPF under high integration of wind power. *Energies* 14(15):4540, URL <http://dx.doi.org/10.3390/en14154540>.
- Leme RP (2017) Gross substitutability: An algorithmic survey. *Games and Economic Behavior* 106:294–316.
- Lété Q, Smeers Y, Papavasiliou A (2022) An analysis of zonal electricity pricing from a long-term perspective. *Energy Economics* 107:105853, ISSN 01409883, URL <http://dx.doi.org/10.1016/j.eneco.2022.105853>.
- Li H, Wang X, Li F, Wang Y, Yu X (2018) A robust day-ahead electricity market clearing model considering wind power penetration. *Energies* 11(7):1772.
- Liberopoulos G, Andrianesis P (2016) Critical review of pricing schemes in markets with non-convex costs. *Operations Research* 64(1):17–31.
- Mas-Colell A, Whinston MD, Green JR, et al. (1995) *Microeconomic theory*, volume 1 (Oxford university press New York).
- McKenzie LW (1959) On the existence of general equilibrium for a competitive market. *Econometrica: Journal of the Econometric Society* 54–71.
- Meeus L, Verhaegen K, Belmans R (2009) Block order restrictions in combinatorial electric energy auctions. *European Journal of Operational Research* 196(3):1202–1206, ISSN 0377-2217, URL <http://dx.doi.org/10.1016/j.ejor.2008.04.031>.
- Milgrom P, Watt M (2021) Linear pricing mechanisms without convexity. URL <https://mitchwatt.github.io/files/PricingMechanismsNonConvex.pdf>.
- Molzahn DK, Hiskens IA (2019) A survey of relaxations and approximations of the power flow equations. *Foundations and Trends® in Electric Energy Systems* 4(1-2):1–221, ISSN 2332-6557, URL <http://dx.doi.org/10.1561/31000000012>.
- NEMO Committee (2020) Euphemia public description. Technical report.
- NEMO Committee (2021) CACM annual report 2020. URL https://www.nemo-committee.eu/assets/files/NEMO_CACM_Annual_Report_2020_deliverable_1_pub.pdf.

- Olivella-Rosell P, Lloret-Gallego P, Munné-Collado Í, Villafafila-Robles R, Sumper A, Ottessen SØ, Rajasekharan J, Bremdal BA (2018) Local flexibility market design for aggregators providing multiple flexibility services at distribution network level. *Energies* 11(4):822.
- O'Neill R, Hytowitz RB, Whitman P, Mead D, Dautel T, Chen Y, Eldridge B, Siskind A, Kheloussi D, Kolkman D, Smith A, Castillo A, Mays J (2019) Essays on average incremental cost pricing for independent system operators.
- O'Neill RP, Castillo A, Eldridge B, Hytowitz RB (2016) Dual pricing algorithm in ISO markets. *IEEE Transactions on Power Systems* 32(4):3308–3310.
- O'Neill RP, Chen Y, Whitman P (2020) The one-pass average incremental cost pricing approach with multi-step marginal costs, ramp constraints and reserves. *Working Paper* .
- O'Neill RP, Sotkiewicz PM, Hobbs BF, Rothkopf MH, Stewart WR (2005) Efficient market-clearing prices in markets with nonconvexities. *European Journal of Operational Research* 1(164):269–285.
- Reihani E, Motaleb M, Thornton M, Ghorbani R (2016) A novel approach using flexible scheduling and aggregation to optimize demand response in the developing interactive grid market architecture. *Applied Energy* 183:445–455.
- Schiro DA, Zheng T, Zhao F, Litvinov E (2016) Convex hull pricing in electricity markets: Formulation, analysis, and implementation challenges. *IEEE Transactions on Power Systems* 31(5):4068–4075, ISSN 0885-8950, URL <http://dx.doi.org/10.1109/TPWRS.2015.2486380>.
- Shah D, Chatterjee S (2020) A comprehensive review on day-ahead electricity market and important features of world's major electric power exchanges. *International Transactions on Electrical Energy Systems* 30(7):e12360.
- Silva-Rodriguez L, Sanjab A, Fumagalli E, Virag A, Gibescu M (2022) A light robust optimization approach for uncertainty-based day-ahead electricity markets. *Electric power systems research* 212:108281.
- Starr RM (1969) Quasi-equilibria in markets with non-convex preferences. *Econometrica: journal of the Econometric Society* 25–38.
- Uçkun C, Botterud A, Birge JR (2015) An improved stochastic unit commitment formulation to accommodate wind uncertainty. *IEEE Transactions on Power Systems* 31(4):2507–2517.
- Zavala VM, Kim K, Anitescu M, Birge J (2017) A stochastic electricity market clearing formulation with consistent pricing properties. *Operations Research* 65(3):557–576.
- Zugno M, Conejo AJ (2015) A robust optimization approach to energy and reserve dispatch in electricity markets. *European Journal of Operational Research* 247(2):659–671.